Outdoor unit	JARXB25C2V1B						
Indoor unit ATXB25C2V1B							
Function			Heating season				
Cooling				Average (mandatory)	Yes		
Heating				Warmer (if designated)	No		
			Colder (if designated)	No			
14	Cb.a.l	Mal	l lade	14	Completed	Malua	11-:4
Item Design Load	Symbol	Value	Unit	Item Seasonal efficiency	Symbol	Value	Unit
Cooling	Pdesignc	2.50	kW	Cooling	SEER	5.93	1
heating / Average	Pdesignh	2.40	kW	heating / Average	SCOP / A	4.01	
heating / Warmer	Pdesignh	2.10	kW	heating / Warmer	SCOP/W	1.01	-
heating / Colder	Pdesignh		kW	heating / Colder	SCOP/C		
Declared capacity* for cooling, at indoor temperature 27(19) °C and outdoor temperature Tj				Declared energy efficiency ratio*, at indoor temperature 27(19) °C and outdoor temperature Tj			
Tj = 35°C	Pdc	2.50	kW	Tj = 35°C	EERd	3.25	Į.
Tj = 30°C	Pdc		kW	Tj = 30°C	EERd		[-
Tj = 25°C	Pdc	1.22	kW	Tj = 25°C	EERd	7.60	-
Tj = 20°C	Pdc	1.15	kW	Tj = 20°C	EERd	9.02	<u>-</u>
and outdoor temperature Tj				Declared coefficient of performance* / Average season, at indoor temperature 20 °C and outdoor temperature Tj			
Tj = -7°C	Pdh	2.13	kW	Tj = -7°C	COPd	2.41	-
Tj = 2°C	Pdh	1.29	kW	Tj = 2°C	COPd	4.03	<b> </b> -
Tj = 7°C	Pdh	0.89	kW	Tj = 7°C	COPd	5.40	ŀ
Tj = 12°C Tj = bivalent temperature	Pdh Pdh	1.02 2.13	kW kW	Tj = 12°C Tj = bivalent temperature	COPd COPd	6.48 2.41	-
Ti = operating limit	Pdh	1.72	kW	Tj = operating limit	COPd	2.31	[
					•		•
and outdoor temperature Tj				Declared coefficient of performance* / Warmer season, at indoor temperature 20 °C and outdoor temperature Tj			
Tj = 2°C	Pdh		kW	Tj = 2°C	COPd		-
Tj = 7°C Tj = 12°C	Pdh Pdh		kW kW	Tj = 7°C Ti = 12°C	COPd COPd		-
Tj = bivalent temperature	Pdh		kW	Tj = bivalent temperature	COPd		[
Tj = operating limit	Pdh		kW	Tj = operating limit	COPd		-
				Declared coefficient of performance* / Colder season, at indoor temperature 20 °C and outdoor temperature Tj			
Tj = -7°C	Pdh		kW	Tj = -7°C	COPd		-
Tj = 2°C	Pdh		kW	Tj = 2°C	COPd		-
Tj = 7°C	Pdh		kW	Tj = 7°C	COPd		-
Tj = 12°C	Pdh		kW	Tj = 12°C	COPd		-
Tj = bivalent temperature	Pdh		kW	Tj = bivalent temperature	COPd		-
Tj = operating limit Tj = -15°C	Pdh Pdh		kW kW	Tj = operating limit Tj = -15°C	COPd COPd		[
[] 10 0	ji dir		KVV	1110 0	joor u		
				Operating limit temperature			
heating / Average	Tbiv	-7	ŀc	heating / Average	Tol	-15	l°C
heating / Warmer	Tbiv		°C	heating / Warmer	Tol		°C
heating / Colder	Tbiv		°C	heating / Colder	Tol		<u>°C</u>
Cycling interval capacity				Cycling interval efficiency			
for cooling	Pcycc		kW	for cooling	EERcyc		-
for heating	Pcych		kW	for heating	COPcyc		-
Degradation co-efficient cooling**	Cdc	0.25	-	Degradation co-efficient cooling**	Cdh	0.25	<u> -</u>
Electric power input in power models other th	an 'active mode'		Annual electricity consumption				
off mode	Poff	0.0	kW	Cooling	QCE	148	kWh/a
standby mode	Psb	0.0	kW	heating / Average	QHE	838	kWh/a
thermostat-off mode	PTO	0.0	kW	heating / Warmer	QHE		kWh/a
crankcase heater mode	PCK	0.0	kW	heating / Colder	QHE		kWh/a
				Out and the second			
Capacity control	NI	ł		Other items		EE / 60	db(A)
fixed	IN.			Sound power level (indoor/outdoor)	└WA	55 / 60	db(A)
staged	N			Global warming potential	GWP	2,087.5	kaccos
9-4				January Potorium		_,	kgCO2eq.
variable	Y			Rated air flow (indoor/outdoor)	-	7.6 / 29.2	m3 <sub>/min</sub>
Contact details for obtaining more information	DAIKIN EUROPE N.V. Zandvoordestraat 300 B-8400 Oostende Belgium						

for staged capacity units, two values divided by a slash (/) will be declared in each box in the section 'Declared capacity of the unit' and 'Declared EER/COP' of the unit.

\*\* if default Cd = 0,25 is chosen then (results from) cycling tests are not required. Otherwise either the heating of cooling cycling test value is required.