Outdoor unit	RXJ25M2V1B						
Indoor unit	FTXJ25MV1BW						
–							
Function	Yes			Heating season	Yes		
Cooling Heating	Yes			Average (mandatory) Warmer (if designated)	No		
				Colder (if designated) No			
14	0			14	0	here	11-14
ltem Design Load	Symbol	Value	Unit	Item Seasonal efficiency	Symbol	Value	Unit
Cooling	Pdesignc	2.40	kW		SEER	8.64	L
heating / Average	Pdesignh	2.70	kW	heating / Average	SCOP / A	4.60	- 1
heating / Warmer	Pdesignh	1.40	kW	heating / Warmer	SCOP / W	5.21	
heating / Colder	Pdesignh		kW	heating / Colder	SCOP / C		
Declared capacity* for cooling, at indoor temperature 27(19) °C and outdoor temperature Tj			Declared energy efficiency ratio*, at indoor temperature 27(19) °C and outdoor temperature Tj				
Tj = 35°C	Pdc	2.40	kW	Tj = 35°C	EERd	4.73	-
Tj = 30°C	Pdc		kW	$T_j = 30^{\circ}C$	EERd		-
Tj = 25°C	Pdc	1.27	kW	Tj = 25°C	EERd	10.55	-
Tj = 20°C	Pdc	1.37	kW	Tj = 20°C	EERd	14.16	-
Declared capacity* for heating / Average season , at indoor temperature 20 °C and outdoor temperature Tj			Declared coefficient of performance* / Average season, at indoor temperature 20 °C and outdoor temperature Tj				
Tj = -7°C	Pdh	2.31	kW	Tj = -7°C	COPd	3.10	-
Tj = 2°C	Pdh	1.40	kW	Tj = 2°C	COPd	4.87	-
Tj = 7°C Tj = 12°C	Pdh Pdh	1.00 0.96	kW kW	Tj = 7°C Tj = 12°C	COPd COPd	5.37 6.36	-
Tj = bivalent temperature	Pan Pdh	2.31	kW	Tj = bivalent temperature	COPd	0.30 3.10	
Tj = operating limit	Pdh	1.95	kW	Tj = operating limit	COPd	2.47	-
Declared capacity* for heating / Warmer season , at indoor temperature 20 °C and outdoor temperature Tj			Declared coefficient of performance* / Warmer season, at indoor temperature 20 °C and outdoor temperature Tj				
Tj = 2°C	Pdh Pdh	1.40	kW kW	Tj = 2°C Tj = 7°C	COPd COPd	4.87	-
Tj = 7°C Tj = 12°C	Pan Pdh	1.00 0.96	kW	I] = 7 C Tj = 12°C	COPd	5.37 6.36	
Tj = bivalent temperature	Pdh	1.40	kW	Tj = bivalent temperature	COPd	4.87	
Tj = operating limit	Pdh	1.95	kW	Tj = operating limit	COPd	2.47	-
				Deplayed coefficient of norfermaneet / Colder concernent indeer termerature 20.00 and auto-			
Declared capacity* for heating / Colder season , at indoor temperature 20 °C and outdoor temperature Tj			Declared coefficient of performance* / Colder season, at indoor temperature 20 °C and outdoor temperature Tj				
Tj = -7°C Ti = 2°C	Pdh Pdh		kW kW	Tj = -7°C Tj = 2°C	COPd COPd		-
Tj = 7°C	Pdh		kW	$T_i = 7^{\circ}C$	COPd		_
$Tj = 12^{\circ}C$	Pdh		kW	$T_j = 12^{\circ}C$	COPd		-
Tj = bivalent temperature	Pdh		kW	Tj = bivalent temperature	COPd		-
Tj = operating limit	Pdh		kW	Tj = operating limit	COPd		-
Tj = -15°C	Pdh		kW	Tj = -15°C	COPd		
Bivalent temperature				Operating limit temperature			
heating / Average	Tbiv	-7	°C	heating / Average	Tol	-15	°C
heating / Warmer heating / Colder	Tbiv Tbiv	2	°C °C	heating / Warmer heating / Colder	Tol Tol	-15	°C °C
	VICT		<u> </u>		101		
Cycling interval capacity			_	Cycling interval efficiency			
for cooling	Pcycc		kW	for cooling	EERcyc		-
for heating Degradation co-efficient cooling**	Pcych Cdc	0.25	kW	for heating Degradation co-efficient cooling**	COPcyc Cdh	0.25	i l
	Cuc	0.20	- F		Cui	0.25	F
Electric power input in power models other	than 'active mode		_	Annual electricity consumption			
off mode	Poff	0.0	kW	Cooling	^Q CE	97	kWh/a
standby mode	Psb	0.0	kW	heating / Average	QHE	822	kWh/a
thermostat-off mode	РТО	0.0	kW	heating / Warmer	ФНЕ	376	kWh/a
crankcase heater mode	РСК	0.0	kW	heating / Colder	QНЕ		kWh/a
					•		
Capacity control	NI			Other items			
fixed	Ν			Sound power level (indoor/outdoor)	└WA	54 (0.000) / 61 (0.000)	db(A)
staged	N			Global warming potential	GWP	675	kgCO 2 eq.
variable	Ν			Rated air flow (indoor/outdoor)	-	8.9 /	m ³ /min
Contact details for obtaining more information * for staged capacity units, two values divided by a slash (/) will be declared in each boy in the section 'Declared capacity of the unit' and 'Declared EER/COP' of the unit							

* for staged capacity units, two values divided by a slash (/) will be declared in each box in the section 'Declared capacity of the unit' and 'Declared EER/COP' of the unit. ** if default Cd = 0,25 is chosen then (results from) cycling tests are not required. Otherwise either the heating of cooling cycling test value is required.